

Nonlinear Aspects of Heat Pump Utilization

R. Najman

Abstract

This work attempts to answer the question: How much can we believe that the coefficient of performance provided by the manufacturer is correct, when a heat pump is required to face the real load coming from changes of temperature? The paper summarizes some basics of heat pump theory and describes the results of numerical models.


Keywords: heat pumps, thermal mass of an object, coefficient of performance.

1 Introduction

The idea of a heat pump is quite old, but nowadays we are confronted with the perspective of a potential energy crisis in the coming decades; people are starting to look for ways to lower their expenditure on domestic heating. A few years ago, when we started studies of this topic, only a few thousand heat pumps were installed in the Czech Republic, but the number has grown by 20–50 % every year. Houses with additional thermal insulation and new insulation windows have spread even more. These installations have a profound impact on the performance of heat pumps.

1.1 Basic principles of heat pumps

Heat pumps use energy from a colder source and release it into a warmer ambience. Almost every refrigerator has one, so we have been living with heat pumps for a long time now.



Legend

- 1 Condenser coil (hot side heat exchanger)
- 2 Expansion valve (gas expands, cools and liquifies)
- 3 Evaporator coil (cold side heat exchanger)
- 4 Compressor
- Red = Gas at high pressure and temperature
- Pink = Gas at high pressure and reduced temperature
- Blue = Liquid at low pressure and greatly reduced temperature
- Light Blue = Gas at low pressure and warmer temperature

Fig. 1: Basic idea of a heat pump [*1]

To describe a heat pump correctly we need the following data: $COP_{heatingB}$, Source of heat, Target medium of heat transition

COP: (efficiency)

$$COP_{heating} = \frac{Q}{P}. \quad (1)$$

Q	Amount of heat transferred to hot reservoir	[W]
$COP_{heating}$	Coefficient of performance (for heating purposes)	[-]
P	Dissipated work of the compressor	[W]

1.2 Source and target of heat

The three typical sources are air, water and soil. The targets are air or water. The systems are therefore referred to as air/air, air/water, water/air, water/water, soil/air and soil/water. For most technical and economic evaluation purposes, the target medium itself does not matter, only its temperature is important.

1.2.1 Sources

Air is the cheapest source for initial investment, but if you do not possess a source with stable temperature (such as warm air from some technological process) the COP is quite low, especially when temperatures outside hit minus values ($^{\circ}C$), or when you need output temperature above $40^{\circ}C$.

Water is the “golden” middle way. It is a cheaper source than soil and its temperature is quite steady through the year, so achievable COP is quite good. Of course, use can be limited by unavailability of a usable water source. In most cases, the water source must be approved by the local authorities.

Soil is the most expensive, but surely the best source for COP. There are many technological ways to obtain heat from soil. The most common way is from drill holes, or from ground collectors. For new build-

ings, a quite cheap and effective way is to use energy pilots (pilots of building foundations with integrated heat collectors).



Fig. 2: Air, water, soil to water heat pumps [*2]

2 Input values and equations

2.1 Subject for testing our mathematical model


Our test subject is a house with a surface area of 400 m² (surfaces with applicable thermal insulation).

Our model heat pump is a water/water type, source water 7 °C (from a well), output 35 °C for a screed floor. After making the first calculation of energy losses, the Stiebel Eltron WPW 7 heat pump seems to be right choice, in combination with some thermal insulation. With no thermal insulation we should use some larger model. Technical data of WPW7: 6.9 kW heat output at 35 °C water and COP 5.2.

2.2 Required heat output

The heat output heat source is calculated according to the following model:

The indoor temperature T_v is maintained by regulating temperature T_1 .



T_1	highest heating temperature	[°C]
T_{wd}	lowest heating temperature	[°C]
T_v	indoor temperature	[°C]
$K_{heating}$	constant representing efficiency of heat transfer	[W/K]
Q_{ven}	heat losses through ventilation	[W]
Q_{iz}	heat losses through walls (insulated)	[W]
Q_{ok}	heat losses through windows	[W]
Q_{TUV}	heat consumed on supply water	[W]

Fig. 3: Heat losses diagram

To calculate the heat losses we need to establish the thermal resistances

$$R_{thv} = \frac{1}{\alpha_v}, \quad R_{thz} = \frac{d}{\lambda_z}, \quad R_{thiz} = \frac{d_{iz}}{1000 \cdot \lambda_{iz}} \quad (2)$$

$$R_{tha} = \frac{1}{\alpha_a}, \quad R_{tho} = \frac{1}{\lambda_o}$$

Where:

R_{thv}	indoor convection thermal resistance	$\left[\frac{\text{K} \cdot \text{m}^2}{\text{W}} \right]$
α_v	indoor heat transfer coefficient	$\left[\frac{\text{W}}{\text{K} \cdot \text{m}^2} \right]$
R_{thz}	thermal resistance of wall	$\left[\frac{\text{K} \cdot \text{m}^2}{\text{W}} \right]$
d	wall width	[m]
λ_z	thermal conductivity of walls	$\left[\frac{\text{W}}{\text{K} \cdot \text{m}} \right]$
R_{thiz}	thermal resistance of walls	$\left[\frac{\text{K} \cdot \text{m}^2}{\text{W}} \right]$
λ_{iz}	thermal conductivity of thermal insulation	$\left[\frac{\text{W}}{\text{K} \cdot \text{m}} \right]$
d_{iz}	thermal insulation width	[mm]
R_{tha}	outdoor convection thermal resistance	$\left[\frac{\text{K} \cdot \text{m}^2}{\text{W}} \right]$
α_a	outdoor heat transfer coefficient	$\left[\frac{\text{W}}{\text{K} \cdot \text{m}^2} \right]$
R_{tho}	thermal resistance of windows	$\left[\frac{\text{K} \cdot \text{m}^2}{\text{W}} \right]$
λ_o	thermal conductivity of windows	$\left[\frac{\text{W}}{\text{K} \cdot \text{m}} \right]$

$$Q_{ok} = S_{ok} \cdot \frac{T_v - T_a}{R_{thv} + R_{tho} + R_{tha}} \quad (3)$$

$$Q_{iz} = S \cdot \frac{T_v - T_a}{R_{thv} + R_{thz} + R_{thiz} + R_{tha}} \quad (4)$$

$$Q_{ven} = 10 \cdot (T_v - T_a) \cdot os \quad \text{-- empiric value} \quad (5)$$

When using a heat pump, the consumption is given by ČSN as follows:

(Heating to 35 °C, and then applying an additional source of heat. With other heat sources than the heat pumps it can be done in one step.)

$$Q_{TUV} = \frac{os \cdot 82 \cdot c_p \cdot (35 - 7)}{3600 \cdot 24} + pom \quad (6)$$


Additional heating up to 55 °C:

$$pom = \frac{os \cdot 82 \cdot c_p \cdot (55 - 35)}{3600 \cdot 24} \quad (7)$$

os number of people [-]

c_p specific heat capacity of water [J/kg · K]

2.3 Heat pump in a thermal circuit



Q_{H_2O-in}	heat taken from the source	[W]
P_{el-HPB}	electricity consumption of HP	[W]
m_2	mass flow the in heating circuit	[kg/s]
T_{wh}	max. temp. of water in the HP	[°C]
P_{el-B}	electricity consumption of a boiler	[W]

(for others, see before)

Fig. 4: Thermal circuit

In the heat pump, the water is heated to T_{wh} (approximately 35°C), then it passes through the water boiler, where it can be heated to T_1 (if necessary). In the screed floor, the temperature of the water goes down to T_{wd} , and the cycle is repeated.

2.4 Equations of the system

$$COP \cdot P_{el-HP} = m_2 \cdot c_p \cdot (T_{wh} - T_{wd}) \quad (8)$$

$$P_{el-B} = m_2 \cdot c_p \cdot (T_1 - T_{wh}) \quad (9)$$

$$Q_{celk} = m_2 \cdot c_p \cdot (T_1 - T_{wd}) \quad (10)$$

$$Q_{celk} = K_{heating} \cdot \left(\frac{T_1 + T_{wd}}{2} - T_v \right) \quad (11)$$


Q_{celk} sum of all heat losses of the object [W]

This system of equations can be solved. The m_2 is chosen from the manufacturer's catalogue. The solutions are as functions of d_{iz} and T_a (from heat loss formulas).

2.5 Thermal mass

The nonlinear behavior of a heat pump (COP is a nonlinear function of the source and target temperature) indicates that the thermal mass of the object must be taken into account. Here I present the algorithm that allows us to estimate the impact of thermal masses on a defined thermal circuit.

The first step is to define the command function, which makes it easy for us to input the desired indoor temperature:



P_{top} heating output [W]

Fig. 5: Heating regulation

The following equations describe the thermal status of the system:

The wall:

$$\rho_s \cdot c_p \cdot \frac{\partial T_s(x, t)}{\partial t} = \lambda_s \cdot \frac{\partial^2 T_s(x, t)}{\partial x^2} \quad (12)$$

With this initial condition

$$T_s(x, 0) = 0 \quad (13)$$

and border conditions

$$\frac{1}{\alpha_a} + \frac{d_{iz}}{\lambda_{iz}} \cdot (T_a(t) - T_s(0, t)) = -\lambda_s \cdot \frac{\partial T_s(x, t)}{\partial x} \Big|_{x=0} \quad (14)$$

$$\alpha_v \cdot (T_s(d, t) - T_v(d, t)) = -\lambda_s \cdot \frac{\partial T_s(x, t)}{\partial x} \Big|_{x=d} \quad (15)$$

Where:

ρ_s	density	[kg/m ³]
c_p	specific heat capacity	[J/kg · K]
T_s	temperature in the wall	[°C]
λ_s	thermal conductivity of wall	[W/K · m]

(for others, see above)

Equations for air, adapted to fit better into Mathematica software:

$$\rho_v \cdot c_p \cdot \frac{\partial T_v(x, t)}{\partial t} = 100 \cdot \frac{\partial^2 T_v(x, t)}{\partial x^2} + \frac{P_{top}(T_v(x, t)) - S \cdot \alpha_v \cdot (T_v(x, t) - T_s(x, t))}{V} - \frac{\rho_v \cdot c_p \cdot (T_v(x, t) - T_a)}{t_v} \quad (16)$$

With the initial condition

$$T_v(x, 0) = 0 \quad (17)$$

and border conditions:

$$\frac{\partial T_v(x, t)}{\partial x} = 0 \Big|_{x \rightarrow 0} \quad (18)$$

$$\frac{\partial T_v(x, t)}{\partial x} = 0 \Big|_{x \rightarrow d} \quad (19)$$

Where:

T_v	air temperature	[°C]
ρ_v	air density	[kg/m ³]
cp_v	air specific heat capacity	[J/kg · K]
S	surface of walls	[S]
V	indoor volume of air	[m ³]
P_{top}	heating output	[W]
t_v	time constant of ventilation	[s]

The solutions to the equations give heating output as a function of time. With sinusoid outdoor temperature in the graph below:




Fig. 6: Heating output

From the part of the solution where transient effects no longer apply, we extract a period of one day $P_{top} = a + b \cdot \sin(\omega t + \varphi)$.

If such heat losses are implemented into the heat pump model described above, we can obtain the dependencies of the variables needed to evaluate the effects of the thermal masses on the heat pump.

Where “red” is the power input of the heat pump, and “black” is the power input of water boiler.

Variant A: outdoor temperature -10 to $+10$ °C, sinus, without thermal mass




Fig. 7: Power inputs, variant A

Variant B: outdoor temperature -10 to $+10$ °C, sinus, with thermal mass




Fig. 8: Power inputs, variant B

Variant C: Outdoor temperature 0 °C




Fig. 9: Power inputs, variant C

If the power inputs are integrated, there is little difference between Var. B (reality) and Var. C. (5.8 %). However, since integrating the full thermal mass including model into our heat pump circuit model would increase the numerical flaws and greatly reduce the stability and reliability of the outcome, we chose from the models according to Var. A (no thermal mass) or Var. C (the thermal mass is so great, that it would negate all changes of temperature during one day). I have chosen to use a curve of input temperatures that it will simulate a system equivalent to variant C. It is very close to reality, and can be solved more precisely with numerical methods in our system of equations.

3 Output values of the heat pump circuit model (for $d_{iz} = 50$ mm)

If the outdoor temperature is stable, the input powers of the heat pump (red) and the water boiler (black) are as follows:




Fig. 10: Power inputs in stable conditions

For choosing the heating period of the year we take the long-term average temperature and compare it with 15 °C.




Fig. 11: Average temperature

For the real effects on a heat pump, we add some oscillations to the outdoor temperature.




Fig. 12: Average temperature with oscillations

This gives us a good display of the consumed power of the heat pump and water boiler in the course of a year. It shows us that the heat pump (red) covers almost all heat losses. The water boiler (black) needs to be switched on only when there is a long period of cold weather.




Fig. 13: Power consumptions in the course of a model year

We also obtain a very significant COP value (red):




Fig. 14: COP in the course of model year

Results

With our input parameters the heat pump worked throughout the year with **COP 4.82**. The heat pump covers almost 100 % of heat consumption with 5 900 kWh per year consumed for heating.

The simplified models give us different results:

The “merchant” model, which is often used by heat pump sellers gives us **COP 5.2**, and energy consumption of 5 400 kWh. It calculates with an average temperature during the heating season.

The “normative” model, which uses $T_a = -15\text{ }^\circ\text{C}$ for the working parameters for heating gives us **COP 2.5** and consumed power of circa 11 000 kWh per year.

This shows that it is worthwhile to investigate heat pumps utilization more deeply. Appropriate use of heat pumps should be considered on the basis of as much factual information as possible.

Acknowledgement

The research described in this paper was supervised by Doc. Dr. Jan Kyncl.

References

- [1] http://en.wikipedia.org/wiki/Heat_pump
- [2] Stiebel, E.: *Heat Pump catalogue 2008*.

Richard Najman
 E-mail: najmaric@fel.cvut.cz
 Dept. of Electroenergetics
 Czech Technical University
 Technická 2, 166 27 Praha, Czech Republic